

CONSOS, INC.

LABORATORY INSPECTION REPORT

P.O. BOX 34186

CHARLOTTE, N.C. 28234

PHONE: (704) 596-2813 FAX: (704) 596-4861

Sheet 1 of 3
QLL 5100

PRODUCT: ULTRA DUCT

SPECIFICATION: MVSS-302 FLAME TEST

IDENTIFICATION & QUANTITY: ONE SAMPLE PO#2083
REPORT #AF071071

PLANT: INNOVATIVE ENERGY
LOWELL, IN

TESTING COMPLETED: JULY 10, 1997

TEST METHODS	RESULTS	REQUIRE.
FLAME TEST:	SAMPLE #	BURN RATE
FOIL SIDE:	TEST #1	IBE
	TEST #2	IBE
	TEST #3	IBE

IBE: IGNITED BUT EXTINGUISHED

I CERTIFY THAT THE ABOVE TESTS WERE PERFORMED UNDER MY SUPERVISION IN ACCORDANCE WITH THE SPECIFIED TEST REQUIREMENTS AND THAT THE REPORTED TEST RESULTS ARE TRUE, VALID AND APPLICABLE TO THE SAMPLES TESTED. I CERTIFY THAT THESE SAMPLES WERE THE ONLY SAMPLES TESTED FROM THE LOT IDENTIFIED ABOVE.

Barbara Fitton

BARBARA FITTON/SUPERVISOR

Beth Herlock

SIGNED: _____
LABORATORY CHIEF / BETH HERLOCK
CONSOS, INC.